



University of Hawaii at Manoa

Environmental Center
Crawford 317 • 2550 Campus Road
Honolulu, Hawaii 96822
Telephone (808) 948-7361

Office of the Director

February 5, 1982

RG:0047

Mr. Michael M. McElroy, Director
Department of Land Utilization
City and County of Honolulu
650 South King Street
Honolulu, Hawaii 96813

Dear Mr. McElroy:

Review of Engineering Reports
Proposed Kaalaea Subdivision
Kaalaea, Koolaupoko, Oahu

With the assistance of Gordon Dugan, Civil Engineering, the Environmental Center has reviewed the engineering reports for the proposed Kaalaea Subdivision with a special emphasis on sewage disposal proposals. At this time, we believe that the given information is insufficient to assess the feasibility of individual lot cesspools.

Before an adequate evaluation can be made, we feel that the following data should be provided:

1. Detailed descriptions of soil types with respect to locations on the project.
2. Quantitative and objective assessments of individual disposal systems in neighboring residential areas.
3. Existing ground and surface water quality conditions to evaluate possible effects of disposal schemes.

We thank you for the opportunity to review this project. If we can be of further assistance, please call.

Yours truly,

Doak C. Cox
Director

cc: Office of Environmental
Quality Control
Gordon Dugan
Jacquelin Miller
David Peterson